

**DEPARTMENT OF PUBLIC SAFETY AND CORRECTIONS****PUBLIC SAFETY SERVICES**

KATHLEEN BABINEAUX BLANCO
GOVERNOR

CHARLES M. FULLER
EXECUTIVE
DIRECTOR

04/03/2007

AD # 1614

TO ALL DEALERS:

WARNING!!!! WARNING!!!! WARNING!!!!

COMPLIANCE AUDITS ARE ONGOING STATEWIDE IN REFERENCE TO FILLING OUT-OF-DATE CYLINDERS, NOT USING SCALES WHEN FILLING CYLINDERS AND OTHER COMMISSION RULES AND REGULATIONS.

STATE POLICE –Transportation and Environmental Safety Section - SPECIAL NOTICE!!!

Please notify T.E.S.S., as a courtesy, prior to flaring any L. P. Gas tanks. Toll free number is 1-877-925-6595.

TO ALL DEALERS “CONDEMNED INSTALLATIONS” – IMPORTANT NOTICE!!!

Any L. P. Gas or Anhydrous Ammonia installation or system found **“NOT”** in compliance with the Revised Statutes or the Commission’s Rules and Regulations will be **“CONDEMNED”** for further use until compliance is achieved. This will be accomplished by posting a **“CONDEMNED INSTALLATION”** decal on the installation or system or by publishing it in the monthly AD letter.

SPECIAL NOTICE!!! SPECIAL NOTICE!! SPECIAL NOTICE!!!

The L. P. Gas Commission requires proof of insurance **on a Commission proprietary certificate of insurance form as of November 1, 2005**. This proprietary certificate of insurance will be provided via facsimile or via mail upon request or can be downloaded from our website at www.dps.state.la.us/lpg/home.html . Insurance requirements are \$1,000,000 in each class of insurance required by Commission rules. If the certificate of insurance is not received on or before the expiration date of your current certificate of insurance, a citation will be issued. Permit holders must “Cease and Desist” L.P. Gas operations immediately, if not received timely.

IMPORTANT NOTICE

SEVERAL NEW RULES AND SOME AMENDED RULES ARE EFFECTIVE NOVEMBER 1, 2005. Please refer to our web site for these new rules and amended rules.

AS A REMINDER TO ALL NEW APPLICANTS, applications must have the complete and correct name of the business on the application and the exact same name on the certificate of insurance. INCORRECT APPLICATIONS CAN NOT BE PROCESSED AND WILL BE RETURNED!!

TRAINING AVAILABLE

****TRAINING ON HOW TO PROPERLY CONDUCT LEAK CHECKS AS WELL AS ANY OTHER SAFETY TRAINING THAT MAY BE NEEDED CAN BE DONE BY ANY INSPECTOR. CONTACT THE INSPECTOR FOR YOUR AREA TO HELP WITH ANY TRAINING.****

******REMINDER****REMINDER******

The L. P. Gas Commission Web Home Page Internet address is www.dps.state.la.us/lpg/home.html .

The Liquefied Petroleum Gas Commission continued its regular meeting on Thursday, March 29, 2007, at 7919 Independence Blvd, Conference Room B, Baton Rouge, LA. The meeting was called to order by the Vice-Chairman, Mrs. Rhonda Watson, with the following members present:

Mr. Greg Morrison, Commissioner
Mr. Jimmy Long, Commissioner

VIOLATIONS

Maxi Mart Inc., 3146 Vet Memorial Dr – ATTN: Tricia Benoit, Abbeville, LA 70510 Docket # 70025

1. Did allow Donald Vincent to fill a DOT cylinder without a card of competency; thus violating R.S. 40:1849 (C)(1) of the Louisiana Revised Statutes of 1950, as amended. Found guilty in absentia and assessed a penalty of \$150.00.

Industrial Weld Sply of Harvey, 111 Buras Dr – ATTN: Owner, Belle Chasse, LA 70037 Docket # 70026

1. Did allow DOT cylinder (Serial #162035A, 12-97) to be filled in unsafe condition (rusted and pitted beyond tolerance); thus violating LAC 55:IX.181 (A), NFPA 58-1995 2-2.1.4 (a) & 2-2.1.6. Found guilty and assessed a penalty of \$1,000.00; Suspend \$500.00 provided there are no further violations for one year.

Taylor Propane Gas Co, P O Box 438 – ATTN: B B Messimer, Winnsboro, TX 75494 Docket # 70027

1. Did allow Ronald J. Perrault Jr. to park trailer (#31) without the use of chock blocks; thus violating LAC 55:IX.181, NFPA 58-1995 6-3.8. Postponed until April.
2. Did allow Ronald J. Perrault Jr. to operate trailer (#31) over the highways of the State of Louisiana with inoperable emergency pull cables; thus violating LAC 55:IX.169. Postponed until April.
3. Did allow Ronald J. Perrault Jr. to operate trailer (#31) over the highways of the State of Louisiana with no fusible link for thermal shut down; thus violating LAC 55:IX.169. Postponed until April.
4. Did allow Ronald J. Perrault Jr. to operate trailer (#31) over the highways of the State of Louisiana without doing a vehicle inspection report; thus violating LAC 55:IX.181(A), NFPA 58-1995 6-3.1.2, CFR 49 396.11. Postponed until April.
5. Did allow Ronald J. Perrault Jr. to transport L.P. gas over the highways of the State of Louisiana (Aug.'06 – Dec.'06) without a proper card of competency; thus violating R.S. 40:1849 (C)(1) of the Louisiana Revised Statutes of 1950, as amended. Postponed until April.

Backus True Value Hardware, 103 N Service Rd East – ATTN: Joe Backus, Ruston, LA 71270 Docket # 70028

1. Did fill an out-of-date DOT cylinder (Serial #L025493, Rect. 1-01E); thus violating LAC 55:IX.181 (E)(10). Postponed until April.
2. Did overfill a DOT cylinder (Serial #003802K); thus violating LAC 55:IX.181 (A), NFPA 58-1995 4-4.2.1. Postponed until April.
3. Did overfill a DOT cylinder (Serial #L025493); thus violating LAC 55:IX.181 (A), NFPA 58-1995 4-4.2.1. Postponed until April.
4. Did fill DOT cylinder (Serial #L025493) with an out-of-date relief valve; thus violating LAC 55:IX.181 (A), NFPA 58-1995 8-3.7. Postponed until April.

Backus True Value Hardware, 103 N Service Rd East – ATTN: Joe Backus, Ruston, LA 71270 Docket # 70029

1. Did overfill a DOT cylinder (Serial #00055984); thus violating LAC 55:IX.181 (A), NFPA 58-1995 4-4.2.1. Postponed until April.
2. Did overfill a DOT cylinder (Serial #L058223); thus violating LAC 55:IX.181 (A), NFPA 58-1995 4-4.2.1. Postponed until April.
3. Did overfill a DOT cylinder (Serial #15256767); thus violating LAC 55:IX.181 (A), NFPA 58-1995 4-4.2.1. Postponed until April.
4. Did fail to provide a charged 18 lbs fire extinguisher as required; thus violating LAC 55:IX.181 (A), NFPA 58-1995 3-10.2.5 & 5-5. Postponed until April.

Ferrellgas LP, 4000 Benton Rd – ATTN: Jim McConathy, Bossier City, LA 71111 Docket # 70030

1. Did fill and allow an out-of-date forklift cylinder (Serial #01234306, 11-94) to remain in service without being requalified; thus violating LAC 55:IX.181 (E)(10). Postponed until April.
2. Did fill and allow a forklift cylinder (Serial #01234306) with an out-of-date relief valve (4-94) to remain in service; thus violating LAC 55:IX.181 (A), NFPA 58-1995 8-3.7. Postponed until April.
3. Did fill and place into service a forklift cylinder (Serial #984781G) that was not properly requalified (Rect 7-04E); thus violating LAC 55:IX.181 (E)(10). Postponed until April.

Ferrellgas LP, 4000 Benton Rd – ATTN: Jim McConathy, Bossier City, LA 71111 Docket # 70031

1. Did allow an out-of-date forklift cylinder (Serial #1234294G, 11-94) to remain in service without being requalified; thus violating LAC 55:IX.181 (E)(10). Postponed until April.
2. Did allow a forklift cylinder (Serial #1234294G) with an out-of-date relief valve (4-94) to remain in service; thus violating LAC 55:IX.181 (A), NFPA 58-1995 8-3.7. Postponed until April.

Ferrellgas LP, 4000 Benton Rd – ATTN: Jim McConathy, Bossier City, LA 71111 Docket # 70032

1. Did service a system (St. Mary Baptist Church) that was improperly installed and was in a dangerous condition; thus violating LAC 55:IX.139 (A). Postponed until April.
2. Did service a system (St. Mary Baptist Church) without performing a proper leak check and inspection after red tagging the system for a leak; thus violating LAC 55:IX.181 (A), NFPA 54-1996 4.1.1 (c). Postponed until April.
3. Did service a system (St. Mary Baptist Church) that did not have proper tank capacity to carry the BTU load; thus violating LAC 55:IX.179 (F). Postponed until April.
4. Did service a system (St. Mary Baptist Church) that did not have proper pipe size to carry the BTU load; thus violating LAC 55:IX.181 (A), NFPA 54-1996 2.4.1. Postponed until April.
5. Did service a system (St. Mary Baptist Church) without an approved sketch; thus violating LAC 55:IX.179 (C)(3). Postponed until April.
6. Did fail to provide documentation of a pressure test & inspection as required; thus violating LAC 55:IX.175. Postponed until April.

7. Did service a system without the required gas utilization equipment shut off valves; thus violating LAC 55:IX.181 (A), NFPA 54-1996 5.5.4. Postponed until April.

Salathe Gas Company LLC, 2226 Peters Rd – ATTN: Stan Salathe, Harvey, LA 70058 Docket # 70033

1. Did place filled DOT cylinders in a cage for sale at (Loves Travel Stops #289) a location not holding a (Class 6X) permit with the Commission; thus violating LAC 55:IX.113 (4). Postponed until April.
2. Did place filled DOT cylinders in a cage for sale (Loves Travel Stops #289) without an approved sketch; thus violating LAC 55:IX.159 (2). Postponed until April.
3. Did place filled DOT cylinders in a cage for sale at (Loves Travel Stops #289) a location that did not have a certificate of insurance on file with the Commission; thus violating LAC 55:IX.107 (3). Postponed until April.

CFJ Enterprise Inc, 6245 Westbank Expwy Ste C47 – ATTN: John Lockett, Marrero, LA 70072 Docket # 70034

1. Did fail to provide a current certificate of insurance as required; thus violating R.S. 40:1847 of the Louisiana Revised Statutes of 1950, as amended. Found guilty in absentia and revoked permit upon rendering evidence and testimony; Eligible to reapply for a permit immediately.

READDRESS: Carter's Neighborhood Supermarket, 8439 Vincent Rd, Denham Springs, LA 70726 Dk # 60144

1. Did continue to engage in the L.P. Gas business without paying the required (Class 6X) permit fee; thus violating R.S. 40:1849 (A) of the Louisiana Revised Statutes of 1950, as amended. Found guilty in absentia, revoked permit upon rendering evidence and testimony, and assessed a penalty of \$250.00 to reapply. Eligible to reapply for a permit immediately upon payment of penalty. **READDRESS:** Commission vacates January 25, 2007, order, accepted guilty plea by waiver, and payment of \$150.00 penalty.

APPLICATIONS

The following applicants for a Name Change were postponed until April 2007:

Clay's R.V. LLC (Class 2) Change To: Clay's R.V. LA Inc. 207 Franklin Dr – ATTN: Jim Smith West Monroe, LA 71292	Atkinson Butane Gas Co. (Class 1) Change To: Atkinson Propane Co. Inc. 4583 Hwy 1147 – ATTN: Fred Atkinson Deridder, LA 70634
Richland Farm Supply Inc. (Class A1) Change To: Jimmy Sanders Inc. 5 Ellis Lane – ATTN: Mike Sanders Rayville, LA 71269	

The following applicants for a Permit were postponed until April 2007:

Cajun Propane of Plain Dealing LLC (Class 1) 901 North Louisiana St – ATTN: Kenneth Lucero Plain Dealing, LA 71064	R.C. Burkhalter Inc. (Class 2) 1896 Harmony Church Rd – ATTN: R. Burkhalter Glennville, GA 30427
Ace Transportation Inc. (Class 7) P O Box 91714 – ATTN: Richard Yandle Lafayette, LA 70509	R.C. Burkhalter Inc. (Class 7) 1896 Harmony Church Rd – ATTN: R. Burkhalter Glennville, GA 30427
Monroe Welding Supply Inc (Class 8) 410 N 18 th St – ATTN: Lee Williams	

Monroe, LA 71201

The following applicants for a Class 2 Permit were heard and are granted by the Commission pending completion of Commission requirements:

HNF Installations Inc. 3414 Wesley St – ATTN: John Smith Greenville, TX 75402	RV Medic 39518 Hornsby Rd – ATTN: Michael Deaton Denham Springs, LA 70706
D & D Emergency Services Inc. 8663 Bellingrath Rd – ATTN: Joe Mooney Theodore, AL 36582	Multi Task LLC 5204 Shreveport Hwy – ATTN: Brian Plunk Pineville, LA 71360
Jesse James 1050 Old DuQuoin Rd – ATTN: Jesse James DuQuoin, IL 62832	Mike Martin Incorporated 1131 N 1800 East Rd – ATTN: Mike Martin Milford, IL 60953

The following applicant for a Class 5 Permit was heard and is granted by the Commission pending completion of Commission requirements:

HNF Installations Inc. 3414 Wesley St – ATTN: John Smith Greenville, TX 75402

The following applicants for a Class 6 Permit were heard and are granted by the Commission pending completion of Commission requirements:

HNF Installations Inc. 3414 Wesley St – ATTN: John Smith Greenville, TX 75402	Pete's Cracklins & Crawfish 5029 Airline Hwy – ATTN: Douglas Pizzolato Baton Rouge, LA 70805
Family RV Factory Outlet 10429 Rock Rd – ATTN: Craig Dunn Hammond, LA 70403	

The following applicant for a Class 7 Permit was heard and is granted by the Commission pending completion of Commission requirements:

Smith Research Corporation 4811 Harding Blvd – ATTN: William Mead Baton Rouge, LA 70811

The following applicants for a Class 6X Permit were heard and are hereby ratified by the Commission:

Smith Research Corporation 2021 Lakeshore Dr New Orleans, LA 70122	Freret Hardware Inc 5109 Freret St New Orleans, LA 70115
Harry's Hardware Inc. 1521 Metairie Rd Metairie, LA 70005	Rithy Inc d/b/a Kimmy's Country Corner 201 N Elm St Haughton, LA 71037
J & D Stores LLC d/b/a Tobacco Stop 2728 W Pinhook Rd Lafayette, LA 70507	Tuban Petroleum LLC d/b/a Birdie's Food & Fuel 1220 Lutchter Ave Lutchter, LA 70071
Covington Mart Inc d/b/a Chevron Jubilee 17178 Hwy 90 West Des Allemands, LA 70030	Harvest Supermarket 12513 Hwy 73 Geismar, LA 70734

Hop-In Texaco 1000 Florida Ave Denham Springs, LA 70726	Ponchatoula Hardware LLC 142 South 8 th St. Ponchatoula, LA 70454
Stephens Country Store & Deli 18105 Hwy 8 Leesville, LA 71446	Vincent's Seafood 62065 Hwy 11 N Slidell, LA 70458
Pioneer Tobacco & Food 30082 Hwy 21 Angie, LA 70426	

The following applicant for a Class 6X Permit requested their application be withdrawn; Commission accepted request:

Stop N Save #19 (Blakley Inc) 1408 North Trenton – ATTN: Tina Rodgers Ruston, LA 71270
--

The following applicants for a Registration Permit were heard and are hereby ratified by the Commission pending completion of Commission requirements:

Lorio's Plumbing LLC (Class R1) 1614 Pomona St – ATTN: David Lorio Metairie, LA 70005	Gootee Construction Co Inc (Class R2) 2400 North Arnoult Rd – ATTN: Eric Alphonso Metairie, LA 70001
---	--

MARCH 2007 **FIRES AND ACCIDENTS**

RELATED: THERE WERE NO RELATED FIRES TO REPORT FOR THE MONTH OF MARCH 2007.

UNRELATED:

FIRE: Herring Gas Co Inc of LA, Ferriday, reported a fire destroyed the residence of Nancy Coates Stockman, Monterey, LA. Fire started from a window a/c unit. No injuries or product loss.

FIRE: Sabine Butane Gas Co, Many, reported a fire destroyed the residence of Brad Patrick, Pleasant Hill, LA. Cause is undetermined at this time. No injuries or product loss reported.

FIRE: Southern LP Gas Inc, Natchitoches, reported a fire destroyed the residence of Kenneth Hill, Campti, LA. Source of fire was electrical. No injuries or product loss.

CONDEMNED/UNCONDEMNED SYSTEMS

THERE WERE NO CONDEMNED/UNCONDEMNED SYSTEMS TO REPORT FOR MARCH 2007.

The Liquefied Petroleum Gas Commission will meet at 2:00 p.m., Wednesday, April 18, 2007, at 7919 Independence Blvd, Conference Room B, Baton Rouge, LA. The meeting is for routine business transpiring during the month and will be continued at 8:30 a.m., Thursday, April 19, 2007, at 7919 Independence Blvd, Conference Room 3000, Baton Rouge, LA. Thursday morning, violations will be heard and applications for permits will be considered.

VIOLATIONS

Taylor Propane Gas Co, P O Box 438 – ATTN: B B Messimer, Winnsboro, TX 75494 Docket # 70027

1. Did allow Ronald J. Perrault Jr. to park trailer (#31) without the use of chock blocks; thus violating LAC 55:IX.181, NFPA 58-1995 6-3.8.
2. Did allow Ronald J. Perrault Jr. to operate trailer (#31) over the highways of the State of Louisiana with inoperable emergency pull cables; thus violating LAC 55:IX.169.
3. Did allow Ronald J. Perrault Jr. to operate trailer (#31) over the highways of the State of Louisiana with no fusible link for thermal shut down; thus violating LAC 55:IX.169.
4. Did allow Ronald J. Perrault Jr. to operate trailer (#31) over the highways of the State of Louisiana without doing a vehicle inspection report; thus violating LAC 55:IX.181(A), NFPA 58-1995 6-3.1.2, CFR 49 396.11.
5. Did allow Ronald J. Perrault Jr. to transport L.P. gas over the highways of the State of Louisiana (Aug. '06 – Dec. '06) without a proper card of competency; thus violating R.S. 40:1849 (C)(1) of the Louisiana Revised Statutes of 1950, as amended.

Backus True Value Hardware, 103 N Service Rd East – ATTN: Joe Backus, Ruston, LA 71270 Docket # 70028

1. Did fill an out-of-date DOT cylinder (Serial #L025493, Rect. 1-01E); thus violating LAC 55:IX.181 (E)(10).
2. Did overfill a DOT cylinder (Serial #003802K); thus violating LAC 55:IX.181 (A), NFPA 58-1995 4-4.2.1.
3. Did overfill a DOT cylinder (Serial #L025493); thus violating LAC 55:IX.181 (A), NFPA 58-1995 4-4.2.1.
4. Did fill DOT cylinder (Serial #L025493) with an out-of-date relief valve; thus violating LAC 55:IX.181 (A), NFPA 58-1995 8-3.7.

Backus True Value Hardware, 103 N Service Rd East – ATTN: Joe Backus, Ruston, LA 71270 Docket # 70029

1. Did overfill a DOT cylinder (Serial #00055984); thus violating LAC 55:IX.181 (A), NFPA 58-1995 4-4.2.1.
2. Did overfill a DOT cylinder (Serial #L058223); thus violating LAC 55:IX.181 (A), NFPA 58-1995 4-4.2.1.
3. Did overfill a DOT cylinder (Serial #15256767); thus violating LAC 55:IX.181 (A), NFPA 58-1995 4-4.2.1.
4. Did fail to provide a charged 18 lbs fire extinguisher as required; thus violating LAC 55:IX.181 (A), NFPA 58-1995 3-10.2.5 & 5-5.

Ferrellgas LP, 4000 Benton Rd – ATTN: Jim McConathy, Bossier City, LA 71111 Docket # 70030

1. Did fill and allow an out-of-date forklift cylinder (Serial #01234306, 11-94) to remain in service without being requalified; thus violating LAC 55:IX.181 (E)(10).

2. Did fill and allow a forklift cylinder (Serial #01234306) with an out-of-date relief valve (4-94) to remain in service; thus violating LAC 55:IX.181 (A), NFPA 58-1995 8-3.7.
3. Did fill and place into service a forklift cylinder (Serial #984781G) that was not properly requalified (Rect 7-04E); thus violating LAC 55:IX.181 (E)(10).

Ferrellgas LP, 4000 Benton Rd – ATTN: Jim McConathy, Bossier City, LA 71111 Docket # 70031

1. Did allow an out-of-date forklift cylinder (Serial #1234294G, 11-94) to remain in service without being requalified; thus violating LAC 55:IX.181 (E)(10).
2. Did allow a forklift cylinder (Serial #1234294G) with an out-of-date relief valve (4-94) to remain in service; thus violating LAC 55:IX.181 (A), NFPA 58-1995 8-3.7.

Ferrellgas LP, 4000 Benton Rd – ATTN: Jim McConathy, Bossier City, LA 71111 Docket # 70032

1. Did service a system (St. Mary Baptist Church) that was improperly installed and was in a dangerous condition; thus violating LAC 55:IX.139 (A).
2. Did service a system (St. Mary Baptist Church) without performing a proper leak check and inspection after red tagging the system for a leak; thus violating LAC 55:IX.181 (A), NFPA 54-1996 4.1.1 (c).
3. Did service a system (St. Mary Baptist Church) that did not have proper tank capacity to carry the BTU load; thus violating LAC 55:IX.179 (F).
4. Did service a system (St. Mary Baptist Church) that did not have proper pipe size to carry the BTU load; thus violating LAC 55:IX.181 (A), NFPA 54-1996 2.4.1.
5. Did service a system (St. Mary Baptist Church) without an approved sketch; thus violating LAC 55:IX.179 (C)(3).
6. Did fail to provide documentation of a pressure test & inspection as required; thus violating LAC 55:IX.175.
7. Did service a system without the required gas utilization equipment shut off valves; thus violating LAC 55:IX.181 (A), NFPA 54-1996 5.5.4.

Salathe Gas Company LLC, 2226 Peters Rd – ATTN: Stan Salathe, Harvey, LA 70058 Docket # 70033

1. Did place filled DOT cylinders in a cage for sale at (Loves Travel Stops #289) a location not holding a (Class 6X) permit with the Commission; thus violating LAC 55:IX.113 (4).
2. Did place filled DOT cylinders in a cage for sale (Loves Travel Stops #289) without an approved sketch; thus violating LAC 55:IX.159 (2).
3. Did place filled DOT cylinders in a cage for sale at (Loves Travel Stops #289) a location that did not have a certificate of insurance on file with the Commission; thus violating LAC 55:IX.107 (3).

Ferrellgas LP, 4000 Benton Rd – ATTN: Jim McConathy, Bossier City, LA 71111 Docket # 70035

1. Did improperly requalify a DOT cylinder (Serial #997422G; Rect 7-04) without the required RIN number; thus violating LAC 55:IX.181 (E)(10) & CFR 49 180.213.

Blue Rhino, 470 West Hanes Mill Rd Ste 200 – ATTN: Susan Simpson, Winston Salem, NC 27105
Docket # 70036

1. Did transport a DOT cylinder in commerce (Serial #A2555132) without proper RIN markings (Marked 0-07F); thus violating LAC 55:IX.181 (E)(10) & CFR 49 180.213.
2. Did transport a DOT cylinder in commerce (Serial # unreadable) without proper RIN markings (RIN stamped extending off cylinder guard); thus violating LAC 55:IX.181 (E)(10) & CFR 49 180.213.

Blue Rhino, 470 West Hanes Mill Rd Ste 200 – ATTN: Susan Simpson, Winston Salem, NC 27105
Docket # 70037

1. Did transport a DOT cylinder in commerce (Serial # unreadable) without proper RIN markings (Marked 0-07F); thus violating LAC 55:IX.181 (E)(10) & CFR 49 180.213.

Emmons Fireplace & More Inc, 9804 Hwy 171 – ATTN: Owner/Manager, Longville, LA 70652
Docket # 70038

1. Did allow Tim Emmons to install a firelog without a card of competency; thus violating R.S. 40:1849 (C)(1) of the Louisiana Revised Statutes of 1950, as amended.
2. Did engage in the LP Gas business without the required permit; thus violating R.S. 40:1847 (A)(1) of the Louisiana Revised Statutes of 1950, as amended.
3. Did service a system without the required gas utilization equipment shutoff valve; thus violating LAC 55:IX.181 (A), NFPA 54-1996 5.5.4.
4. Did fail to provide documentation of a pressure test and inspection as required; thus violating LAC 55:IX.175 (8).
5. Did install a gas fire log not in accordance with the manufacturing instruction; thus violating LAC 55:IX.177 (B)(1).

Total Plumbing Company, 160 Hoffpauir Rd – ATTN: Randall Fontenot, Ragley, LA 70657 Docket # 70039

1. Did fail to provide documentation of a pressure test and inspection as required; thus violating LAC 55:IX.181 (A), NFPA 54-1996 6.1 (a).

Blossman Gas of LA Inc., P O Box 1110 – ATTN: Permits & Licenses, Ocean Springs, MS 39566
Docket # 70040

1. Did continue to engage in the L.P. Gas business without paying the required (Class 1) permit fee; thus violating R.S. 40:1849 (A) of the Louisiana Revised Statutes of 1950, as amended.

Cameco Industries, 244 Hwy 3266 – ATTN: Dewey Gravois, Thibodaux, LA 70301 Docket # 70041

1. Did continue to engage in the L.P. Gas business without paying the required (Class 2) permit fee; thus violating R.S. 40:1849 (A) of the Louisiana Revised Statutes of 1950, as amended.

Cancienne Plumbing Inc., 25 Hickory Ave – ATTN: Christian Cancienne, Harahan, LA 70123 Docket # 70042

1. Did continue to engage in the L.P. Gas business without paying the required (Class 2) permit fee; thus violating R.S. 40:1849 (A) of the Louisiana Revised Statutes of 1950, as amended.

CFJ Enterprises Inc, 6245 Westbank Expressway Ste C– ATTN: John Lockett, Marrero, LA 70072 Docket # 70043

1. Did continue to engage in the L.P. Gas business without paying the required (Class 7) permit fee; thus violating R.S. 40:1849 (A) of the Louisiana Revised Statutes of 1950, as amended.

CH2MHill Constructors Inc, 1515 Poydras St Suite 2110–ATTN:G Kerin, New Orleans, LA 70112 Docket # 70044

1. Did continue to engage in the L.P. Gas business without paying the required (Class 2) permit fee; thus violating R.S. 40:1849 (A) of the Louisiana Revised Statutes of 1950, as amended.

CH2MHill Constructors Inc, 1515 Poydras St Suite 2110–ATTN:G Kerin, New Orleans, LA 70112 Docket # 70045

1. Did continue to engage in the L.P. Gas business without paying the required (Class 6X) permit fee; thus violating R.S. 40:1849 (A) of the Louisiana Revised Statutes of 1950, as amended.

Cyclone Cylinder Exchange, P O Box 995 – ATTN: D Edwin Williams, Brookshire, TX 77423 Docket # 70046

1. Did continue to engage in the L.P. Gas business without paying the required (Class 4) permit fee; thus violating R.S. 40:1849 (A) of the Louisiana Revised Statutes of 1950, as amended.

Granny's Seafood & Deli, 19008 Hwy 22 – ATTN: Mike Fortune, Ponchatoula, LA 70454 Docket # 70047

1. Did continue to engage in the L.P. Gas business without paying the required (Class 6) permit fee; thus violating R.S. 40:1849 (A) of the Louisiana Revised Statutes of 1950, as amended.

Jubilee Food Store – Lafayette, 2727 W Pinhook – ATTN: Manager, Lafayette, LA 70508 Docket # 70048

1. Did continue to engage in the L.P. Gas business without paying the required (Class 6X) permit fee; thus violating R.S. 40:1849 (A) of the Louisiana Revised Statutes of 1950, as amended.

KC's Grocery & Bait Shop, 1889 Hwy 318 – ATTN: Ella Mathews, Jeanerette, LA 70544 Docket # 70049

1. Did continue to engage in the L.P. Gas business without paying the required (Class 6X) permit fee; thus violating R.S. 40:1849 (A) of the Louisiana Revised Statutes of 1950, as amended.

Kornbread's Korner, P O Box 383 – ATTN: Patricia Gongre, Montgomery, LA 71454 Docket # 70050

1. Did continue to engage in the L.P. Gas business without paying the required (Class 6X) permit fee; thus violating R.S. 40:1849 (A) of the Louisiana Revised Statutes of 1950, as amended.

Loranger Super Foods, P O Box 500 – ATTN: Bart Palmisano, Loranger, LA 700446 Docket # 70051

1. Did continue to engage in the L.P. Gas business without paying the required (Class 6) permit fee; thus violating R.S. 40:1849 (A) of the Louisiana Revised Statutes of 1950, as amended.

Martino K Inc., 35902 Hwy 16 – ATTN: Henry Nguyen, Montpelier, LA 70422 Docket # 70052

1. Did continue to engage in the L.P. Gas business without paying the required (Class 6X) permit fee; thus violating R.S. 40:1849 (A) of the Louisiana Revised Statutes of 1950, as amended.

APPLICATIONSThe following applicants have applied for a Name Change:

Clay's R.V. LLC (Class 2) Change To: Clay's R.V. LA Inc. 207 Franklin Dr – ATTN: Jim Smith West Monroe, LA 71292	Atkinson Butane Gas Co. (Class 1) Change To: Atkinson Propane Co. Inc. 4583 Hwy 1147 – ATTN: Fred Atkinson Deridder, LA 70634
Richland Farm Supply Inc. (Class A1) Change To: Jimmy Sanders Inc. 5 Ellis Lane – ATTN: Mike Sanders Rayville, LA 71269	Vernon's Hardware # 2 (Class 6) Change To: Vernon's Hardware Denham 31568 LA Hwy 16 – ATTN: Craig Chenevert Denham Springs, LA 70726

The following applicant has applied for a Class 1 Permit:

Cajun Propane of Plain Dealing LLC 901 North Louisiana St – ATTN: Kenneth Lucero Plain Dealing, LA 71064
--

The following applicants have applied for a Class 2 Permit:

R.C. Burkhalter Inc.
1896 Harmony Church Rd – ATTN: R. Burkhalter
Glennville, GA 30427

The following applicants have applied for a Class 6 Permit:

Bordelon Corp Inc d/b/a Pine Crest RV & MH Park 2601 Old Spanish Trail – ATTN: Carol Bordelon Slidell, LA 70461	Total Supply LLC 677 W 10 th St – ATTN: Joseph Accardo Reserve, LA 70084
Lee's Landing Marina 38068 Lee's Landing Rd – ATTN: Danny Wallace Ponchatoula, LA 70454	Blue Dog Bait Inc. P O Box 2082 – ATTN: Lyn Willingham Slidell, LA 70459

The following applicants have applied for a Class 7 Permit:

R.C. Burkhalter Inc. 1896 Harmony Church Rd – ATTN: R. Burkhalter Glennville, GA 30427	Ace Transportation Inc. P O Box 91714 – ATTN: Richard Yandle Lafayette, LA 70509
HNF Installations Inc. 3414 Wesley St – ATTN: John Smith Greenville, TX 75402	

The following applicant has applied for a Class 8 Permit:

Monroe Welding Supply Inc 410 N 18 th St – ATTN: Lee Williams Monroe, LA 71201	
---	--

The following applicants have applied for a Class 6X Permit and are to be ratified by the Commission:

Mr. Quik of Bush 81550 Hwy 21 Bush, LA 70431	Starks Truck Stop 4344 Louisiana Hwy 12 Starks, LA 70661
B & B Grocery 1002 Hwy 107 Centerpoint, LA 70323	U Pak It Campbells #427 (Campbell) 1872 Memullen St Hwy 167 Dubach, LA 71235
Jalou d/b/a Relay Station #86 1011 N Arkansas St Springhill, LA 71075	Bud's Grocery 7213 Hwy 465 Simpson, LA 71474

The following applicant has applied for a Class A4E Permit and is to be ratified by the Commission :

Werner Transportation Services Inc P O Box 7171 – ATTN: Stephen DePue Jr. Gainesville, GA 30504	
---	--

The following applicant has applied for a Class A4 Permit :

Werner Transportation Services Inc
P O Box 7171 – ATTN: Stephen DePue Jr.
Gainesville, GA 30504

SPECIAL NOTICE : IT IS REQUIRED THAT ALL NEW CLASS 6 APPLICANTS ATTEND THE SAFETY MEETING IMMEDIATELY FOLLOWING THE THURSDAY COMMISSION HEARING.

NOTICE : ALL APPLICANTS FOR NEW PERMITS MUST HAVE A REPRESENTATIVE (OWNER, MANAGER OR OFFICER) AT THE MEETING ON THURSDAY, APRIL 19, 2007, AT 7919 INDEPENDENCE BLVD, CONFERENCE ROOM 3000, BATON ROUGE, LOUISIANA. THE ONLY EXCEPTIONS ARE CLASS 6-X, R-1 & R-2 REGISTRATIONS, 7-E & A4-E EMERGENCY PERMITS AND NAME CHANGES FOR SUCH.

BY ORDER OF THE
LIQUEFIED
PETROLEUM GAS
COMMISSION

CHARLES M. FULLER
DIRECTOR