



DEPARTMENT OF PUBLIC SAFETY AND CORRECTIONS

PUBLIC SAFETY SERVICES

M. J. "MIKE" FOSTER,
JR.
GOVERNOR

CHARLES M. FULLER
EXECUTIVE
DIRECTOR

05/13/2003

AD # 1567

TO ALL DEALERS:

STATE POLICE –Transportation and Environment Safety Section - SPECIAL NOTICE!!!

Please notify T.E.S.S., as a courtesy, prior to flaring any L. P. Gas tanks. Their toll free number is 1-877-925-6595. This is a courtesy to State Police for any incoming calls they may receive and good public relations with the public.

TO ALL DEALERS “CONDEMNED INSTALLATIONS” - IMPORTANT NOTICE!!!

Any L. P. Gas or Anhydrous Ammonia installation or system found **“NOT”** in compliance with the Revised Statutes or the Commission’s Rules and Regulations will be **“CONDEMNED”** for further use

until compliance is achieved. This will be accomplished by posting a **“CONDEMNED**

INSTALLATION” decal on the installation or system or by publishing it in the monthly AD letter.

SPECIAL NOTICE!!! **SPECIAL NOTICE!!!** **SPECIAL NOTICE!!!**

The L. P. Gas Commission requires proof of insurance in the office on or before the expiration date on the certificate of insurance. If the certificate of insurance is not received on or before the expiration date a citation will be issued. Permit holders must “Cease and Desist” L.P. Gas operations immediately.

IMPORTANT NOTICE FOR ALL NEW APPLICATIONS FOR PERMITS:

NEW APPLICANTS MUST HAVE THE COMPLETE AND CORRECT NAME OF THE BUSINESS ON THE APPLICATION AND THE EXACT SAME NAME ON THE CERTIFICATE OF INSURANCE. INCORRECT APPLICATIONS WILL BE RETURNED.

WARNING!!!! **WARNING!!!!** **WARNING!!!!**

UNDERCOVER OPERATIONS ARE ON GOING STATEWIDE IN REFERENCE TO FILLING OF OUT OF DATE CYLINDERS AND NOT USING SCALES WHEN FILLING CYLINDERS. BEWARE!!!!!!!!!!

ATTN: ALL PERMIT HOLDERS

Please be advised that any document submitted to the Commission from all permit holders must contain the EXACT dealer name on their permit that was approved by the Commission.

*****REMINDER ***REMINDER*****

The L. P. Gas Commission Web Home Page Internet address is www.dps.state.la.us/lpg/home.html.

The Liquefied Petroleum Gas Commission continued its regular meeting Thursday, April 24, 2003 at 7919 Independence Blvd., 1st Floor –Conference Room D, Baton Rouge, Louisiana. The meeting was called to order by the Chairman with the following members present:

Mr. James Hopson, Chairman

Mr. Kenneth Weber, Vice-Chairman

Mr. Donald Kiper, Commissioner

Mr. John Montecino, Commissioner

also present were the Director, Charles Fuller and various dealers.

VIOLATIONS

Madisonville Amoco, 201 Hwy. 22 West-ATTN: Carl Vickers, Madisonville, LA 70447, Docket #30063

1. Did fail to pay civil penalty imposed by the Commission within thirty days after final assessment; thus violating R.S. 40:1848 (B) of the Louisiana Revised Statutes of 1950, as amended. Permit revoked; Defendant may reapply for permit after payment of penalties assessed on Docket #20057.

Scott Petroleum Corp., 102 Main St.-ATTN: Joey Johnson, Itta Bena, MS 38941, Docket #30064

1. Did place system into service without submitting required sketch for approval; thus violating LAC 55:IX.179 (A). Found guilty and assessed a fine of \$500.

D & H Marine Service, 1911 Melrose-ATTN: Dal Sanders, Pineville, LA 71360, Docket #30065

1. Did allow employee, Dal Sanders, to fill an out-of-date DOT L.P. Gas Cylinder; thus violating LAC 55:IX.181 (E) (10). Found guilty and assessed a fine of \$300.00, with suspension of \$150.00.

McManus Auto, P.O. Box 314-ATTN: Royce McManus, Montgomery, LA 71454, Docket #30066

1. Did allow employee, Darren McManus, to fill an out-of-date DOT L.P. Gas Cylinder; thus violating LAC 55:IX.181 (E) (10). Found guilty in absentia and assessed a fine of \$400.00.

Dalbis Meat Market & Grocery, 307 East Lincoln Rd ATTN: Chris Reed, Ville Platte, LA 70586,

Docket #30067

1. Did allow employee, Christopher Reed, to fill an out-of-date DOT L.P. Gas Cylinder; thus violating LAC 55:IX.181 (E) (10). Found guilty and assessed a fine of \$300.00.
-

John's Food Mart, 1075 Chicot Park Rd., ATTN: Wilfred John LaHaye, Ville Platte, LA 70586, Docket #30068

1. Did allow employee, Thomas Thrasher, Jr., to fill an out-of-date DOT L.P. Gas Cylinder; thus violating LAC 55:IX.181 (E) (10). Found guilty and assessed a fine of \$300.00.
2. Did allow employee, Thomas Thrasher, Jr. to fill a DOT L. P. Gas cylinder without a card of competency; thus violating R.S. 40:1849 (C) (1). Found guilty and assessed a fine of \$150.00.
3. Did allow employee, Thomas Thrasher, Jr. to fill a DOT L. P. Gas cylinder without the use of scales; thus violating LAC 55:IX. 181 (E) (8). Found guilty and assessed a fine of \$300.00.

B & S Corner Groc. & Meat Mkt., 1914 Main St. ATTN: Bobby Dupre, Ville Platte, LA 70586, Docket #30069

1. Did allow employee, Clarence Fontenot, to fill an out-of-date DOT L.P. Gas Cylinder; thus violating LAC 55:IX.181 (E) (10). Found guilty and assessed a fine of \$300.00
2. Did allow employee, Clarence Fontenot, to fill a DOT L. P. Gas cylinder without a card of competency; thus violating R.S. 40:1849 (C) (1) of the Louisiana Revised Statutes of 1950, as amended. Found guilty and assessed a fine of \$150.00.
3. Did allow employee, Clarence Fontenot, to fill a DOT L. P. Gas cylinder without the use of scales; thus violating LAC 55:IX. 181 (E) (8). Found guilty and assessed a fine of \$300.00.
4. Did allow employee, Clarence Fontenot, to overfill a 20 lb Dot L.P. Gas cylinder; thus violating LAC 55:IX.181 (A), NFPA 58, 4-4.2.1. Found guilty and assessed a fine of \$300.00.

Duhon Hardware Inc., 6584 West bank Expressway, ATTN: Charles Lindsey, Marrero, LA 70072, Docket #30070

1. Did have filled and transported DOT L.P. gas cylinders without proper permit; thus violating LAC 55:IX.113.7. Found guilty and assessed a fine of \$500.00.
2. Did place in service an exchange cage without sketch being submitted and finalized; thus violating LAC 55:IX.179. Found guilty and assessed a fine of \$500.00.
3. Did place into service an exchange cage that was not located at least five feet from any doorway in a building; thus violating LAC 55:IX.181 (A), NFPA 58, 5-4.1. Found guilty and assessed a fine of \$500.00.

Paul's Meat Market & Groc., 1319 Chataignier Rd., ATTN: Allen P. Fontenot, Ville Platte, LA 70586, Docket #30071

1. Did allow employee, Danny Guillory, to fill an out-of-date DOT L.P. Gas Cylinder; thus violating LAC 55:IX.181 (E) (10). Found guilty and assessed a fine of \$300.00.
2. Did allow employee, Danny Guillory, to fill a DOT L. P. Gas cylinder without a card of competency; thus violating R.S. 40:1849 (C) (1). Found not guilty and Charge dismissed.
3. Did allow employee, Danny Guillory, to overfill a 20 lb. DOT L. P. Gas cylinder ; thus violating LAC 55:IX. 181 (A), NFPA 58, 4-4.2.1. Found guilty and assessed a fine of \$300.00.

APPLICATIONS

There were no applications received for a name change.

The following application for a Class 2 permit was amended to a Class 6 permit and was heard and is hereby granted by the Commission pending completion of Commission requirements.

Riverview R.V. Park LLC 100 Riverview Parkway Vidalia, LA 71373	
---	--

The following application for a Class 5 permit was postponed until the May hearing.

M.C. Forklift Services, Inc. P.O. Box 3563 Houma, LA 70361	
--	--

The following application for a Class 6 permit was postponed until the May hearing.

Cajun Coast Truck Stop & Casino, LLC P.O. Box 791665 New Orleans, LA 70179	
--	--

The following applications for a Class 6 permit were heard and are hereby granted by the Commission pending completion of Commission requirements.

Diamond E. Saddle Shop & Hardware, Inc. P.O. Box 333 Walker, LA 70785	Pitre's Enterprise, Inc. 5026 Hwy. 56 Chauvin, LA 70344
---	---

Lil' Joe's Fast Lane 9928 Hwy 34 Eros, LA 71238	
---	--

The following applications for Class 6x permits were heard and are hereby ratified by the Commission:

Pablo's, LLC 2490 Morganza Hwy. New Roads, LA 70760	Exxon Deli Express 9731 Hwy. 182 E. Amelia, LA 70340
---	--

Busy Bee Grocery, LLC P.O. Box 366 Florien, LA 71429	Robeline Food Mart P.O. Box 148 Robeline, LA 71469
B & K Seafood 7338 Haynes Blvd. New Orleans, LA 70126	

The following application for a Class 7 permit was heard and is hereby granted by the Commission, pending completion of Commission requirements:

CW Transport LLC 1998 I-45 South New Waverly, TX 77358
--

APRIL, 2003

FIRES AND ACCIDENTS

RELATED:

There were no related fires reported.

UNRELATED:

FIRE: Scott Petroleum, Lake Providence, reported a fire destroyed the mobile home of Gertrude Peterson, Oak Grove. The cause of the fire is believed to have been caused by an electrical short in kitchen. There was no loss of product and no injuries were reported.

FIRE: Harrell Gas Inc., Kentwood, reported a fire damaged Buddy's Seafood, Kentwood. The cause of the fire is believed to be electrical. There was no loss of product and no injuries were reported.

FIRE: Aeropres Propane Inc., Coushatta, reported a fire destroyed the mobile home of Quida Colley, Coushatta. The cause of the fire is unknown. There was no loss of product and no injuries were reported.

FIRE: Herring Gas Co. Inc. of La, Ferriday, reported a fire destroyed the mobile home of Chester Verbeck, Clayton. The cause of the fire is unknown. There was no loss of product and no injuries were reported.

FIRE: O'Neal Gas Inc., Choudrant, reported a fire damaged the mobile home of Linda Russell, Farmerville. The cause of the fire is from a grease fire. There was no loss of product and no injuries were reported.

FIRE: Ferrellgas, Lafayette, reported a fire destroyed the La Pac building, Crowley. The cause of the fire is unknown. There was loss of product and no injuries were reported.

FIRE: Herring Gas, Franklinton, reported a fire destroyed the home of David Foy, Tickfaw. The cause of the fire is unknown. Loss of product and injuries are unknown.

FIRE: Herring Gas Co., Inc of LA, reported a fire destroyed the mobile home of Glen Davis, Franklinton. The cause of the fire is unknown. There was no loss of product and no injuries were reported.

FIRE: O'Nealgas Inc., Choudrant, reported a fire destroyed the home of James Stephenson, Bernice. The cause of the fire is believed to be electrical. There was no loss of product and no injuries reported.

FIRE: Harrell Gas Inc., Kentwood, reported a fire damaged the home of Brian Annison, Zachary. The cause of the fire is believed to be from stove. There was loss of product, no injuries reported.

FIRE: Herring Gas Co. Inc., Jena, reported a fire destroyed the mobile home of Austin Walker, Pollock. The cause of the fire is unknown. There was no loss of product and no injuries reported.

ACCIDENT: Ferrellgas reported an at-fault accident. Driver pulled out of a driveway, turned right onto highway and crossed over into other lane to avoid falling off driveway and turning over. Driver was struck by an oncoming vehicle.

INCIDENT: Inspector John Nicholas reported theft of Anhydrous Ammonia at West Louisiana Ice Co.

APRIL, 2003

CONDEMNED SYSTEMS

Inspector Chad Ledet condemned eleven Anhydrous Ammonia tanks and uncondemned two Anhydrous Ammonia tanks described as follows:

1. 7031 gal. Delta Anhydrous Ammonia tank, located at Herman Walet Bros., Loreauville, LA, Serial #96 T, temporarily condemned due to no safety equipment, no water, no markings, needs paint, signs to be redone, ESV inoperable, mark ESV.
2. 5000 gal. Mississippi Anhydrous Ammonia tank, located at Levert Mercantile Co, St. Martinville, LA, Serial #0001, temporarily condemned due to no safety equipment, no water, tank no longer in use, needs painting, needs signs, relief valves to be checked.
3. 5,000 gal. Mississippi Anhydrous Ammonia tank, located at Levert Mercantile Co., St. Martinville, Serial #0002, temporarily condemned due to no safety equipment, no water, tank no longer in use, needs painting, needs signs, relief valves to be checked.
4. 23,846 gal. McNammar Anhydrous Ammonia tank, located at Levert Mercantile Co., St. Martinville, Serial #X-497-1, temporarily condemned due to no safety equipment, no water, tank no longer in use, needs painting, needs signs, relief valves to be checked.
5. 23,846 gal. McNammar Anhydrous Ammonia tank, located at Levert Mercantile Co., St. Martinville, Serial #X-375-3, temporarily condemned due to no safety equipment, no water, tank no longer in use, needs painting, needs signs, relief valves to be checked
6. Unknown size and Manufacturer of Anhydrous Ammonia tank, located at Valentine Farm, Serial # unknown, permanently condemned due to no data plate, piping rusted out, out of use for four years, owner wants to do away with tank.
7. Unknown size and Manufacturer of Anhydrous Ammonia tank, located at St. Vincent Gulf Shrimp Company Inc., Serial # unknown, permanently condemned due to no data plate and tank is extremely pitted.
8. 8,000 gal. Delta Anhydrous Ammonia tank, located at Gravois Farms Inc., Paulina, Serial

#11269, temporarily condemned due to tank not properly marked, no safety equipment, and open piping with no plug.

9. 6,000 gal. Beaird Anhydrous Ammonia tank, located at D & R Blanchard Farms Inc., Belle Rose, Serial #W-3112-4, Permanently condemned due to tank converted to diesel.

10. 6,000 gal. Beaird Anhydrous Ammonia tank, located at D & R Blanchard Farms Inc., Belle Rose, Serial #W-3112-2, Permanently condemned due to tank converted to diesel.

11. 12,000 gal. Delta Anhydrous Ammonia tank, located at Gravois Farms Inc., Belle Rose, Serial #249347, temporarily condemned due to no water and no safety equipment.

UNCONDEMNED TANKS:

1. 6000 gal. Beaird Anhydrous Ammonia tank, located at Clement Bro., Hwy. 87, Charenton, LA, Serial #W 50881.

2. 6000 gal. Delta Anhydrous Ammonia tank, located at Clement Bro., Hwy. 87, Charenton, LA, Serial #541665.

Inspector Len Hodges uncondemned two Anhydrous Ammonia gas tanks described as follows:

1. 8000 gal. Delta Anhydrous Ammonia tank, located at St. Louis Planting Inc., 3105 St. Louis Rd., Plaquemine, LA, Serial #17735.

2. 18,004 gal. Beaird Anhydrous Ammonia tank, located at St Louis Planting Inc., 3105 St. Louis Rd., Plaquemine, LA, Serial #27379.

The Liquefied Petroleum Gas Commission will meet at 2:00 p.m., Wednesday, May 28, 2003 at 7919 Independence Blvd., 1st Floor-Conference Room D, Baton Rouge, Louisiana. The meeting is for routine business transpiring during the month and will be continued at 8:30 a.m., Thursday, May 29, 2003 at 7919 Independence Blvd., 1st Floor-Conference Room D, Baton Rouge, Louisiana. At the Thursday morning meeting violators will be dealt with and applications will be considered.

VIOLATIONS

Dansby's Taylor Rental Center LLC, 2102 Forsythe Ave.-ATTN: Thomas C. Dansby, Sr., Monroe, LA 71201, Docket #30068

1. Did allow employee, Tom Dansby, to fill an out-of-date DOT L.P. Gas Cylinder; thus violating LAC 55:IX.181 (E) (10).

Henry's Lawn and Garden LLC-Monroe, 1375 Hwy 139-ATTN: Henry Cook, Monroe, LA 71203, Docket #30069

1. Did allow employee, Henry R. Cook, to fill an out-of-date DOT L.P. Gas Cylinder ; thus violating LAC 55:IX.181 (E) (10).

C & J Farm and Ranch Supply Inc. 6301 Hwy 165 Bypass South-ATTN: Donna Jinks, Monroe, LA 71202, Docket #30070

1. Did allow employee, Ronald G. Nobles, to fill an out-of-date DOT L.P. Gas Cylinder; thus violating LAC 55:IX.181 (E) (10).
2. Did allow Ronald G. Nobles to return a filled cylinder without an effective seal, this violating LAC 55:IX.181 (A), NFPA 58-1995,4-2.2.2.

Country Livin, 104 Cleo Drive-ATTN: David St. Clair, Pineville, LA 71360, Docket #30071

1. Did allow employee, Suzanne M. Prater, to fill an out-of-date DOT L.P. Gas Cylinder (8-96E) without being requalified; thus violating LAC 55:IX.181 (E) (10).

L & A One Stop, P.O. Box 265-ATTN: A.D. Paul, Deville, LA 71328, Docket #30072

1. Did allow employee, Aubry D. Paul Sr., to fill an out-of-date DOT L.P. Gas Cylinder (2-80) without being requalified; thus violating LAC 55:IX.181 (E) (10).

Denville Grocery, P.O. Box 93-ATTN: Gary Grant, Deville, LA 71328, Docket #30073

1. Did allow employee, Annette V. Myers, to fill an out-of-date DOT L.P. Gas Cylinder (12-90) without being requalified; thus violating LAC 55:IX.181 (E) (10).
2. Did allow employee, Annette V. Myers, to fill a DOT L.P. Gas Cylinder without the required card of competency; thus violating R.S. 40:1849 (C) (1) of the Louisiana Revised Statutes of 1950, as amended.

Herring Gas Co Inc of LA, P.O. Box 308-ATTN: Doug Grissom, Meadville, MS 39653, Docket #30074

1. Did place tank in service without submitting required installation report; thus violating

LAC 55:IX.159.1.

2. Did place tank in service without submitting the required sketch for approval; thus violating

LAC 55:IX. 179 (A).

Lowe's, P.O. Box 1111-ATTN: Tosha Hall, N Wilkesboro, NC 28656, Docket #30075

1. Did place in service an exchange cage without sketch being submitted and finalized; thus violating LAC 55:IX.179.
2. Did place into service an exchange cage that was not located at least five feet from any doorway in a building; thus violating LAC 55:IX.181 (A), NFPA 58, 5-4.1.

Blue Rhino Corp., 104 Cambridge Plaza Drive-ATTN: Susan Simpson, Winston Salem, NC 27104, Docket #30076

1. Did service an exchange cage without sketch being submitted and finalized; thus violating LAC 55:IX.179.
2. Did service an exchange cage that was not located at least five feet from any doorway in a building; thus violating LAC 55:IX.181 (A), NFPA 58, 5-4.1.

Ferrellgas LP, 3876 Industrial Circle-ATTN: Al Lanius, Bossier City, LA 71112, Docket #30077

1. Did fill an out-of-date DOT L.P. Gas Cylinder (9-90); thus violating LAC 55:IX.181 (E) (10).

Ferrellgas LP, 3876 Industrial Circle-ATTN: Al Lanius, Bossier City, LA 71112, Docket #30078

1. Did recertify and fill a Dot L.P. Gas Fork Lift Cylinder (3-03E), Serial #862489G, without installing a new relief valve; thus violating LAC 55:IX.181 (A), NFPA 58 2-3.2.5 and 8-3.7.
2. Did recertify and fill a Dot L.P. Gas Fork Lift Cylinder (4-03E), Serial #862434G, without installing a new relief valve; thus violating LAC 55:IX.181 (A), NFPA 58 2-3.2.5 and 8-3.7.
3. Did recertify and fill a Dot L.P. Gas Fork Lift Cylinder (3-03E), Serial #861965G, without installing a new relief valve; thus violating LAC 55:IX.181 (A), NFPA 58 2-3.2.5 and 8-3.7.
4. Did recertify and fill a Dot L.P. Gas Fork Lift Cylinder (3-03E), Serial #843804G, without installing a new relief valve; thus violating LAC 55:IX.181 (A), NFPA 58 2-3.2.5 and 8-3.7.
5. Did recertify and fill a Dot L.P. Gas Fork Lift Cylinder (4-03E), Serial #785276G, without installing a new relief valve; thus violating LAC 55:IX.181 (A), NFPA 58 2-3.2.5 and 8-3.7.
6. Did recertify and fill a Dot L.P. Gas Fork Lift Cylinder (4-03E), Serial #1037438G, without installing a new relief valve; thus violating LAC 55:IX.181 (A), NFPA 58 2-3.2.5 and 8-3.7.
7. Did recertify and fill a Dot L.P. Gas Fork Lift Cylinder (4-03E), Serial #867318G, without installing a new relief valve; thus violating LAC 55:IX.181 (A), NFPA 58 2-3.2.5 and 8-3.7.

Ferrellgas LP, 3876 Industrial Circle-ATTN: Al Lanius, Bossier City, LA 71112, Docket #30079

1. Did allow employee, James LaForest, to deliver L.P. Gas without the use of a meter or suitable weighing device; thus violating LAC 55:IX.165 (A).

Superior Oil & Lube LLC, P.O. Box 218-ATTN: Joseph Loughman, Marksville, LA 71351, Docket#30080

1. Did allow employee, Beau Vincent Loughman, to fill an out-of-date DOT L.P. Gas Cylinder

(1-90), without being requalified; thus violating LAC 55:IX.181 (E) (10).

2. Did allow employee, Beau Vincent Loughman, to fill a DOT L.P. Gas Cylinder without the required card of competency; thus violating R.S. 40:1849 (C) (1) of the Louisiana Revised Statutes of 1950, as amended.

3. Did allow employee, Beau Vincent Loughman, to overfill a DOT L.P. Gas Cylinder; thus violating LAC 55:IX.181.A-NFPA 58-1995,4-4.2.1.

Marksville Lil Quickie, P.O. Box 753-ATTN:Ibrahim Ghannam, Marksville, LA 71351, Docket #30081

1. Did allow employee, Lisa A. Dauzat, to fill an out-of-date DOT L.P. Gas Cylinder (2-80), without being requalified; thus violating LAC 55:IX.181 (E) (10).

2. Did allow employee, Lisa A. Dauzat, to overfill a DOT L.P. Gas Cylinder; thus violating LAC 55:IX.181.A-NFPA 58-1995,4-4.2.1.

Dauzat's Shopping Center, 5890 Hwy. 107-ATTN:Ardie Dauzat, Marksville, LA 71351, Docket #30082

1 Did allow employee, Sherman Aymond, to fill an out-of-date DOT L.P. Gas Cylinder (11-90), without being requalified; thus violating LAC 55:IX.181 (E) (10).

2. Did allow employee, Sherman Aymond, to fill a DOT L.P. Gas Cylinder without the required card of competency; thus violating R.S. 40:1849 (C) (1) of the Louisiana Revised Statutes of 1950, as amended.

APPLICATIONS

The following applicants have applied for a name change:

H & H Appliance Sales and Service Change to: H & H Appliance Sales and Service, L.L.C. PO Box 728 Lecompte, LA 71346	Gulf King Seafood, Inc. Change to: Ocean Shrimp, LLC PO Box 287 Empire, LA 70050
---	--

The following applicant has applied for a Class 2 Permit:

Byrnes Mechanical Contractors, Inc. 115 Ridgedale Drive West Monroe, LA 71291	
---	--

The following applicant has applied for a Class A2 Permit:

San-Tech, Inc.	
----------------	--

P.O. Box 879 West Monroe, LA 71294

The following applicant has applied for a Class 5 Permit:

M.C. Forklift Services Inc. P.O. Box 3563 Houma, LA 70361

The following applicants have applied for a Class 6 Permit:

Cajun Coast Truck Stop & Casino, L.L.C. P.O. Box 791665 Walker, LA 70785	Southern Pro Home Center P.O. Box 689 Churchpoint, LA 70525
Pride One Stop P.O. Box 66 Pride, LA 70770	Taylor's Amelia Superette L.L.C. PO Box 396 Amelia, LA 70340
Spillway Sportsman, Inc. PO Box 156 Brusly, LA 70719	Head of Island Grocery 18939 Hwy 22 Maurepas, LA 70449

The following applicants have applied for a Class 6x permit and are to be ratified by the Commission:

SMW, Inc. DBA Belle Chasse Self Serve 9654 Hwy. 23 Belle Chasse, LA 70037	Port Sulphur Ace Hardware 27274 Hwy. 23 Port Sulphur, LA 70083
Stumpf's Supermarket, Inc. P.O. Box 604 Venice, LA 70091	Amar Oil Co. DBA Swifty's 1612 West Church St. Hammond, LA 70401
Superior Grocery and Meat Market P.O. Box 5 Joyce, LA 71440	Jack's Beverages #10 712 Terry Parkway Gretna, LA 70056

The following applicants have applied for a Class R2 Registration and are to be ratified by the Commission:

Bonar Engineering & Construction Company 565 S. Edgewood Ave. Jacksonville, FL 32205

SPECIAL NOTICE: IT IS REQUIRED THAT ALL NEW CLASS 6 APPLICANTS ATTEND THE SAFETY MEETING IMMEDIATELY FOLLOWING THE THURSDAY MORNING COMMISSION HEARING.

NOTICE: ALL APPLICANTS, WHETHER FOR NEW PERMITS OR CHANGE OF NAME, MUST HAVE A REPRESENTATIVE (OWNER, MANAGER OR OFFICER) AT THE MEETING ON THURSDAY, MAY29, 2003 AT 7919 INDEPENDENCE BLVD., 1ST FLOOR-CONFERENCE ROOM D, BATON ROUGE, LA. THE ONLY EXCEPTIONS ARE CLASS 6-X AND ANHYDROUS AMMONIA WHO PRESENTLY HOLD A PERMIT WITH THIS COMMISSION.

BY ORDER OF LIQUEFIED

PETROLEUM GAS COMMISSION

CHARLES M. FULLER

DIRECTOR